

WALTER A. TILLIT, JR., P.E.

tilteco@aol.com FL P.E. License No. 44167 FL C.A. License No. 0006719

PRODUCT EVALUATION REPORT

REPORT No.:

22-0329.01

DATE:

March 29, 2022

PRODUCT CATEGORY:

Windows

PRODUCT SUB-CATEGORY:

Horizontal Slider

PRODUCT NAME:

SERIES 18000 HIGH IMPACT HORIZONTAL

SLIDING WINDOW LARGE MISSILE IMPACT

RESISTANT

1. PURPOSE OF EVALUATION:

This is a Product Evaluation Report issued by Walter A. Tillit, Jr., P.E.

(System ID # 1906) based on Rule Chapter No. 61G20-3,

Method 1D of the Florida Department of Business and Professional Regulation.

This product is being issued an Evaluation Report as described herein and has been verified for compliance in accordance with the 2020 Seventh Edition of the Florida Building Code, and to verify that the product is for the purpose intended at least equivalent to that required by the Code.

This Product Evaluation Report shall be subject to review and revision in Case Building Code change that may affect its limitations and conditions.

No. 44167

STATE OF

SORIDA

6355 N.W. 36th Street, Suite 305, Miami, Florida 33166 - Phone: (305) 871-1530 - Fax: (305) 871-1531

2. EVIDENCE SUBMITTED:

2.1. PRODUCT EVALUATION DOCUMENT (P.E.D.):

Drawing No. 22-017, titled "SERIES 18000 HIGH IMPACT HORIZONTAL SLIDING WINDOW LARGE MISSILE IMPACT RESISTANT" sheets 1 thru 14 of 14 prepared by Tilteco, Inc.; signed and sealed by Walter A. Tillit, Jr., P.E.; dated 03/29/2022. This drawing is an integral part of this Evaluation Report.

2.2. TEST REPORTS:

Impact and Cyclic Tests as per protocol TAS-201, TAS-203, Uniform Static Load as per Protocol TAS 202 per sections 1626 and 1609.1.2, respectively of the Florida Building Code.

Test reports prepared by Fenestration Testing Lab Inc., Report No.5954, signed and sealed by Julio E Gonzalez, P.E.

2.3. STRUCTURAL ENGINEERING CALCULATIONS:

On Series 18000 high impact horizontal sliding window large missile impact resistant for Maximum Pressure Rating vs. Maximum anchor spacing, maximum width and height, and Maximum Glass Size, based on rational and comparative analysis, in accordance with sections 1604 and 1616 of the Florida Building Code. Calculations prepared by Tilteco, Inc., dated 06/04/2015, signed and sealed by Walter A. Tillit, Jr., P.E.

3. MISSILE IMPACT RESISTANCE:

Large Missile Impact resistance is provided per TAS 201 (9 lbs., 50 feet/sec, Large Missile).

4. WIND LOADS RESISTANCE:

On Series 18000 high impact horizontal sliding window large missile impact resistant has been verified to keep sustain wind pressures. Maximum Glass Panel Dimensions, window dimensions shall be as indicated on sheet 12 of Product Evaluation Document (P.E.D.), Drawing No. **22-017.**

5. INSTALLATION:

Installation shall be performed strictly in accordance with General Notes # 2 thru 13, indicated on sheet 1 and details indicated on sheets 4 thru 11 and 13 and 14 of Product Evaluation Document (P.E.D.), drawing No. 22-017.

Gaskets and setting blocks used at installations comply with section 2411.3.4 of the Florida Building Code as specified on Bill of Materials on Sheet 3 of Production, Evaluation Document (P.E.D.), drawing No. 22-017.

No. 44167

6. MATERIAL CHARACTERISTICS AND SPECIFICATIONS:

Shall be strictly in accordance with General Notes and Components indicated on sheets 2 and 3, of Product Evaluation Document (P.E.D.), **Drawing No. 22-017.**

Anchor specifications shall be as indicated on sheet 1, of Product Evaluation Document (P.E.D.), Drawing No. **22-017.** Max anchor spacing shall be per sheet 12 of P.E.D. No **22-017.**

7. LIMITATIONS AND CONDITIONS OF USE:

- 7.1. Shall be strictly in compliance with General Notes No. 1 thru 5, indicated on sheet 1 of Product Evaluation Document (P.E.D.), Drawing No.**22-017** prepared by Tilteco, Inc. and signed and sealed by Walter A. Tillit, Jr., P.E.
- 7.2. Product **may** be installed within HIGH VELOCITY HURRICANE ZONES as defined on section 202 of the Florida Building Code and out of it.
- 7.3. Product shall only be installed into substrates with limitations as indicated on sheet 12 of Product Evaluation Document (P.E.D.), Drawing No. **22-017**.

Product Evaluation Report prepared by Walter A. Tillit, Jr., P.E. (Florida License No. 44167), President of Tilteco, Inc. (Florida CA-0026719).

WAT\ma

D:\TILTECO ADMON RECORDS \ P. E. REPORT.22 \ MIAMI DADE ALUMINUM, CORP \ SERIES 18000 HIGH IMPACT HORIZONTAL SLIDING WINDOW LARGE MISSILE IMPACT RESISTANT\ DRWG # 22-017 \ REPORT # 22-0329.01

No. 44167

STATE OF

STATE